

## **Addendum #1**

### **TOWN OF YORKVILLE**

### **Braun Road Tile Replacement Project**

**Date: August 20, 2018**

#### **CHANGES TO PLANS (PAGE 5 OF 7)**

**Modification to Note:** 50' – 4" PVC Drain Tile @ 0.96% Compacted Granular Backfill IE 4" (N) 761.70 / IE. 4" (S) 761.38

**ADD: Schedule 40, Non-Perforated**

**\*\*NOTE: Please acknowledge receipt of Addendum No. 1 on page 3 of the Bidder's Proposal \*\***



Nielsen Madsen + Barber

CIVIL ENGINEERS AND LAND SURVEYORS